



### 1 Fire blanket (min. 120 x 180cm)

A fire blanket must be available at every food stall (food preparation).

### 2 Fire extinguisher (from 3 kg light water or CO2 extinguisher)

Every sales stand has a tested fire extinguisher. EVERY 3 years or according to manufacturer's instruction



### 3 Non-combustible underlay

Every sales stand must be equipped with a non-combustible underlay, unless the storage surface is made of chrome steel or similar. E.g. Eternit or metal plate



### 5 Burner test:

For gas burners, a valid gas vignette and test certificate must be present before the appliance can be put into operation! Appliances with an invalid vignette must not be put into operation. Outdated or brittle connection hoses must be replaced. See special agreement on liquid gas.

- Visitors at risk must be protected with a contact guard.
- Appliances operated with liquid gas are to be set up outdoors.

### 4 Passages to buildings

Passages must be kept clear at all times and must not be obstructed. The building clearance of 120 cm must be observed. Only if the entrance is not clear.



### 6 Fire brigade

Stands may not be extended at will. The stand sizes must be adhered to. The fire brigade and other emergency services must be able to operate unhindered at all times. Rescue access routes must be kept clear and hydrants, fire extinguishing posts and the like must be accessible and ready for use at all times.

### 7 Escape route from the sales stand

Escape routes from the tent or the sales stand must be free and accessible at all times.

The escape route must not be blocked or obstructed by exposed installations or other structures.

### 9 Decorations at the sales stand

Do not use flammable decorations. (Such as straw, hay, paper, reeds, fir branches).

It is not permitted to use rain/sun roofs, stands etc. to enlarge the stand.

To enlarge the stand.



### 8 Electrical installations

Electrical installations must be installed in such a way that there is no danger to persons or living creatures.

Cable reels completely unrolled. (cable fires).

Do not use defective connectors and cables. (incl. plug connectors).

Cable routing must be installed correctly.

Never connect more than 2 connector strips together. Protect electrical installations against moisture.

### GENERAL INFO

All mentioned safety elements will be checked by the market management. If there are any complaints, the market management reserves the right not to release the sales stand until the deficiencies have been rectified.